



Product Service

CERTIFICATE

No. B 09 09 66677 002

Holder of Certificate: **ELECTROTHERMIKI
YIANNIS SIPSIS S.A.**62, Dramas Str.
185 43 Piraeus
GREECE

Production Facility(ies): 66677

Certification Mark:



Product: Valve

Model(s): **electro mechanical regulation valves
JES, JES Super**

Parameters:	Rated voltage:	230V AC, 50 Hz
	Rated power:	3,5 W
	Rated pressure:	16 bar
	Type of protection:	class II (JES), class I (JES Super)
	Degree of protection:	IP20
	Temperature range of liquid medium:	5 °C - 65 °C
	Connection:	open wire ends

Tested according to: EN 60730-2-8/A1:2003

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 71353540

Date, 2009-09-17

Page 1 of 1

